



Flam-Guard 300 Range

Enhanced Fire Resistant Multi Core Cable

(Complies with BS 7629-1:2015)

Class 1 Solid Copper Conductor or Class 2 Stranded Copper Conductor/
Silicone Rubber Insulation / MICA Fire Barrier Tape / Aluminum
Electrostatic Screen/ Tinned Copper Circuit Protective Conductor/
Low Smoke Zero Halogen Sheath

Application

Enhanced fire-resistant cables are designed for safety systems which need to operate during multi-phase evacuations such as tower blocks, multi-story buildings or dense public buildings such as hospitals. Suitable for fire detection and fire alarm systems with 'enhanced' performance conforming to BS 5839-1 Code of Practice. Suitable for emergency lighting systems with 'enhanced' performance conforming to BS 5266-1 Code of Practice.

Manufactured with Low Smoke Zero Halogen (LSZH) insulation, making it suitable for installations in public buildings where, in the event of fire, smoke and acid gas evolution would pose a hazard to public life and equipment.

Cable Description

Class 1 Solid Copper Conductor to BS EN 60228 for 1.5mm²
Class 2 Stranded Copper Conductor to BS EN 60228 for 2.5mm² - 4.0mm²
Silicone Rubber Insulation Type EI2 to BS EN 50363
MICA (Fire Barrier) Overall Tape
Aluminum Electrostatic Screen
Tinned Copper circuit protective conductor
Low Smoke Zero Halogen Sheath



N.B. In the event of fire, the gases evolved from this cable are free from Halogen and the design is optimised to limit the quantity and cleanliness of the smoke evolved during this period. Although the acronym HFFR is applied to the sheath material, the terms LSOH, HFFR and HFFR are also applicable.

Insulation Colours

2 Core - Blue, Brown,

3 Core - Brown, Black, Grey

4 Core - Blue, Brown, Black, Grey

Sheath Colours

White / Red (Other Colours Available on Request)

Third party Accreditation



Cables are tested and approved by BASEC (British Approvals Service for Cables)



Cables are tested and approved by LPCB (Loss Prevention Certification Board)

British Cables Company Limited, Delaunays Road, Blackley, Manchester, M9 8FP, United Kingdom

Tel: +44 (0) 161 741 2345 | Fax: +44 (0) 161 795 8393 | Web: www.britishcablescompany.com | Email: info@britishcables.com

Disclaimer: Great effort is made to ensure the accuracy of the information presented, but errors may occur.

Specification and availability should be confirmed with a call to our sales representatives. ©British Cables company Limited



Physical Characteristics

No of Conductors	Nominal Cross-Sectional Area (mm ²)	Nominal Radial Thickness Insulation (mm)	Nominal Radial Thickness Sheath (mm)	Approximate Overall Diameter (mm)	Maximum Conductor Resistance at 20°C (ohms/km)	Nominal Weight (kg/km)
2	1.5	0.70	0.90	8.50	12.10	93.00
2	2.5	0.80	1.00	10.50	7.41	135.00
2	4.0	0.80	1.10	12.50	4.61	190.00
3	1.5	0.70	0.90	9.50	12.10	130.00
3	2.5	0.80	1.00	11.50	7.41	180.00
3	4.0	0.80	1.10	13.50	4.61	250.00
4	1.5	0.70	1.00	10.50	12.10	150.00
4	2.5	0.80	1.10	12.00	7.41	210.00
4	4.0	0.80	1.20	15.00	4.61	330.00

Mechanical Characteristics

Characteristics	Unit	Value
Max Conductor Temperature	°C	70 (*90)
Min Operating Temperature	°C	-40
Min Installation Temperature	°C	0
Max Installation Temperature	°C	70
Minimum Bend Radius	Diameter	6D

* Cable installed in an enclosure, subject to the sheath being terminated upon entry and the combination of ambient temperature and temperature rise due to load resulting in a conductor temperature not exceeding 70 °C outside the enclosure, the conductor temperature in the enclosure can be increased to a temperature not exceeding 90 °C.

Electrical Characteristics - General

Characteristics	Unit	Value
Voltage Rating	V	300/500
Current Rating Table	-	4D2

Electrical Characteristics – Current Carrying Capacity

CONDUCTOR CROSS – SECTIONAL AREA	REFERENCE METHOD A (ENCLOSED IN CONDUIT THERMALLY INSULATING WALL ETC)		REFERENCE METHOD B (ENCLOSED IN CONDUIT ON A WALL OR IN TRUNKING ETC)		REFERENCE METHOD C (CLIPPED DIRECT)		REFERENCE METHOD E (IN FREE AIR OR ON A PERFORATED CABLE TRAY ETC, HORIZONTAL OR VERTICAL)	
	1 TWO CORE CABLE*, SINGLE PHASE AC OR DC	1 THREE CORE CABLE* OR 1 FOUR CORE CABLE, THREE-PHASE AC	1 TWO CORE CABLE*, SINGLE PHASE AC OR DC	1 THREE CORE CABLE* OR 1 FOUR CORE CABLE, THREE-PHASE AC	1 TWO CORE CABLE*, SINGLE PHASE AC OR DC	1 THREE CORE CABLE* OR 1 FOUR CORE CABLE, THREE-PHASE AC	1 TWO CORE CABLE*, SINGLE PHASE AC OR DC	1 THREE CORE CABLE* OR 1 FOUR CORE CABLE, THREE-PHASE AC
1	2	3	4	5	6	7	8	9
(mm ²)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)
1.5	14	13	16.50	15	19.50	17.50	22	18.50
2.5	18.50	17.50	23	20	27	24	30	25
4	25	23	30	27	36	32	40	34

The above is in accordance with 18th edition of the IET wiring regulations.

Fire Performance

Test	Test Method	Comment
Construction Standard	BS 7629-1	Compliant
Circuit Integrity (PH120) – Flame & Shock 120 mins	BS EN 50200:2015	Compliant
Circuit Integrity– Flame, Shock & Water 120 mins	BS 8434-2	Compliant
Circuit Integrity– Category 3 Rating	BS 8519:2020 Annex D	Compliant
Circuit Integrity Test	BS 6387 C,W,Z	Compliant
Single Cable Vertical Burn Test	BS EN 60332-1: 2004	Compliant
Acid Gas Emission	BS EN 60754-1:2014	Compliant
Smoke Emission	BS EN 61034-2: 2005	Compliant